

OPERATIONS PERMIT

Name: (owner) George Jones

New Installation

Septic Tank

Property Location: SR# 1521

Repairs

Nitrification Line

Subdivision _____

Lot # 1+2

TAX ID# _____

Quadrant # _____

Contractor: Rocky Holland

Registration # _____

Basement with Plumbing:

Garage:

Water Supply: Well

Public

Community

Distance From Well: 50' ft.

Following are the specifications for the sewage disposal system on above captioned property.

Type of system: Conventional

Other _____

Size of tank: Septic Tank: 1000 gallons

Pump Tank: _____ gallons

Subsurface Drainage Field No. of ditches 3 exact length of each ditch 115 ft. width of ditches 3 ft. depth of ditches 18-24 in.


French Drain: _____ Linear feet

10343

Date: 10-13-96

PERMIT NO. ~~10343~~

Inspected by: James E. Maxhant
Environmental Health Specialist



IMPROVEMENT PERMIT

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department".

Name: (owner) George Jones New Installation Septic Tank
Property Location: SR# 1571 Repairs Nitrification Line

Subdivision _____ Lot # 102 combined

Tax ID# _____ Quadrant # _____

Number of Bedrooms Proposed: 3 Lot Size: 1.06 ac

Basement with Plumbing: Garage:

Water Supply: Well Public Community

Distance From Well: 50' ft.

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system: Conventional Other _____

Size of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallons

Subsurface Drainage Field No. of ditches 3 exact length of each ditch 115 ft. width of ditches 3 ft. depth of ditches 18-24 in.

French Drain required: _____ Linear feet


This permit is subject to revocation if site plans or intended use change.

Date: 7-3-96

Signed: Thomas J. Boyer R.S.

Environmental Health Specialist

Maintain Setbacks
Install lower line at 18"



SR 1521