

HTE# _____

HARNETT COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH
307 CORNELIUS HARNETT BOULEVARD
LILLINGTON, NC 27546

EXISTING SEPTIC SYSTEM INSPECTION

NAME: ATLANTIC Roofing + Construction PHONE # 919-801-8426

ADDRESS 192 Joseph Alexander Dr. F.V. N.C. 27509

NAME OF MOBILE HOME PARK OR S/D Jonathon's Ridge lot

NAME OF OWNER (IF DIFFERENT) Ricky Darnell BURCH

ADDRESS OF OWNER (IF DIFFERENT) 12 ADRIAN ST Holly Springs N.C.

PROPERTY LOCATION: STATE ROAD NAME AND # SR1452 Truax Rd

PURPOSE OF INSPECTION:

Covered Pch + Deds 9'x4' + 12'x12' + 12'x8'

The aforementioned site has been evaluated by the Harnett County Health Department Environmental Health Section. At the time of inspection, there appeared to be a septic system serving this site. If this system should malfunction, the owner is responsible for any necessary repairs.

THIS INSPECTION IS VOID IF:

- (1) the intended use of the septic system should change, and/or
- (2) the system should fail or malfunction, and/or
- (3) the owner or tenant of the property changes, and/or
- (4) after six months

**BUILDING MUST BE 5' FROM ANY PART OF SEPTIC SYSTEM
DO NOT DRIVE OR PARK ON SEPTIC SYSTEM**

AUTHORIZATION OF EXISTING SYSTEM

James E. Marshall JR REAS
Signature of Environmental Health Specialist

8-20-18
Date