

HTE# _____

HARNETT COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH
307 CORNELIUS HARNETT BOULEVARD
LILLINGTON, NC 27546

EXISTING SEPTIC SYSTEM INSPECTION

NAME: John Wilson PHONE # 910-984-5089

ADDRESS 211 Faircloth W Broadway, N.C. 27505

NAME OF MOBILE HOME PARK OR S/D SOUTH RIDGE Farm lot 33

NAME OF OWNER (IF DIFFERENT) Mitchell McDONALD + JOEL Leach

ADDRESS OF OWNER (IF DIFFERENT) 155 SmokeTree Tr. F.V. N.C. 27526

PROPERTY LOCATION: STATE ROAD NAME AND # Hwy 401 N

PURPOSE OF INSPECTION:

10x18' Covered Porch

The aforementioned site has been evaluated by the Harnett County Health Department Environmental Health Section. At the time of inspection, there appeared to be a septic system serving this site. If this system should malfunction, the owner is responsible for any necessary repairs.

THIS INSPECTION IS VOID IF:

- (1) the intended use of the septic system should change, and/or
- (2) the system should fail or malfunction, and/or
- (3) the owner or tenant of the property changes, and/or
- (4) after six months

**BUILDING MUST BE 5' FROM ANY PART OF SEPTIC SYSTEM
DO NOT DRIVE OR PARK ON SEPTIC SYSTEM**

AUTHORIZATION OF EXISTING SYSTEM

James E. Mawhinney ENV 17548
Signature of Environmental Health Specialist

Date