



Harnett County
420 McKinney Pkwy
LILLINGTON, NC 27546
Phone:
Fax:

6/15/2022

SUBJECT: BRES1808-0031
BUILDING RESIDENTIAL

To: ALTAMIRANO PEDRO GARCIA

Here are the results of all Inspections located at **181 ALLEN RD:**

Inspection Type: SEWER CONNECTION
Scheduled Date/Time:
Completed Date/Time:
Inspector: Scott Guy
Result:
Remarks:
Notes:

Inspection Type: TAX INSPECTION
Scheduled Date/Time:
Completed Date/Time:
Inspector: Unassigned
Result:
Remarks:
Notes:

Inspection Type: WATER CONNECTION
Scheduled Date/Time:
Completed Date/Time:
Inspector: Scott Guy
Result:
Remarks:
Notes:

Inspection Type: ADDRESS
Scheduled Date/Time: 3/3/2022
Completed Date/Time: 3/3/2022
Inspector: GIS Bucket
Result: APPROVED
Remarks:
Notes: 181 ALLEN RD SANFORD 27332.



Harnett County
420 McKinney Pkwy

LILLINGTON, NC 27546
Phone:
Fax:

Inspection Type: MH FOUND/MARRIAGE WALL

Scheduled Date/Time: 3/7/2022

Completed Date/Time: 3/7/2022

Inspector: Steven Gazlay

Result: DISAPPROVED

Remarks:

Notes: All trades under home must be roughed in, no plumbing drain installed. All piping must terminate outside of skirting. Insulate water line under home.

Inspection Type: MH FOUND/MARRIAGE WALL

Scheduled Date/Time: 3/24/2022

Completed Date/Time: 3/24/2022

Inspector: Steven Gazlay

Result: DISAPPROVED

Remarks:

Notes: Water heater drain and hvac condensate cannot terminate under home.

Inspection Type: MH FOUND/MARRIAGE WALL

Scheduled Date/Time: 4/14/2022

Completed Date/Time: 4/14/2022

Inspector: Steven Gazlay

Result: APPROVED

Remarks:

Notes:

Inspection Type: ZONING

Scheduled Date/Time: 5/16/2022

Completed Date/Time: 5/16/2022 10:30 AM

Inspector: Kyle Holder

Result: APPROVED

Remarks:

Notes:

Inspection Type: ENVIR OPERATIONS PERMIT

Scheduled Date/Time: 6/7/2022

Completed Date/Time: 6/7/2022

Inspector: Mark Osborne

Result: APPROVED

Remarks:

Notes:



Harnett County
420 McKinney Pkwy

LILLINGTON, NC 27546

Phone:

Fax:

Inspection Type: FINAL**
Scheduled Date/Time: 6/9/2022
Completed Date/Time: 6/9/2022
Inspector: Steven Gazlay
Result: DISAPPROVED

Remarks:

Notes: Provide address numbers on home. Missing weather proof cover on exterior outlet. Sewer piping must have 3" dirt on top minimum. Cannot use 2x6 for handrails on porch. Door locked unable to gain access to inspect interior.

Inspection Type: FINAL**
Scheduled Date/Time: 6/20/2022
Completed Date/Time:
Inspector: Steven Gazlay
Result:
Remarks:
Notes: