

November 20, 2018

Michelle Smith
5613 Hardwick Lane
Fayetteville, NC 28306

Re: Status of Improvement Permit Application– BRES1808-0063R

Ms. Smith,

An attempt was made to evaluate your property for the purpose of issuing an Improvement Permit. The evaluation could not be completed for one or more of the following reasons.

- 1. Use pink flags to mark property lines and irons that are set by surveyor need to be visible. *(\$25.00 fee incurred)*
- 2. Use orange flags to mark house corners *(\$25.00 fee incurred)*
- 3. Directions not clear to property *(\$25.00 fee incurred)*
- 4. Property needs only brush or vegetation removed
- 5. Driveway not shown on site plan
- 6. Backhoe pits required
- 7. **Other- Revision required- DWMH shall be 70ft setback off front property line (including any front porch). Decks/porches shall be included on site plan (if applicable). Proposed system and repair flagged onsite. Revision paperwork required.**

Your application will be put on hold until the selected items above have been addressed. When completed **please call 910-893-7547 to confirm** that the items mentioned have been corrected, we will then reschedule your property for evaluation.

Sincerely,



Andrew Currin, R.E.H.S
Environmental Health Specialist
Harnett County Department of Public Health

AC/kh
Copy: Central Permitting