

Harnett County

108 EAST FRONT STREET

LILLINGTON, NC 27546

Phone: Fax:

10/3/2019

SUBJECT: **BRES1809-0035**

BUILDING RESIDENTIAL

To: Josh Sturtz Homes

Here are the results of all Inspections located at 54 WILLIAM BETHUNE CT:

Inspection Type: ROUGH IN
Scheduled Date/Time: 10/10/2018
Completed Date/Time: 10/10/2018
Inspector: Jimmy Hall
Result: DISAPPROVED

Remarks:

Notes: OK to side for rough in inspection all electrical boxes need to be installed & all plumbing needs

to be installed like tubs and tested

Inspection Type: ROUGH IN
Scheduled Date/Time: 10/29/2018
Completed Date/Time: 10/29/2018
Inspector: Jimmy Hall
Result: APPROVED

Remarks: Notes:

Inspection Type: ROUGH IN
Scheduled Date/Time: 12/17/2018
Completed Date/Time: 12/17/2018
Inspector: Ken Slattum
Result: APPROVED

Remarks:

Notes: bldg., elect plumb rough ins

Please call Travis at 910-633-5984

Inspection Type: INSULATION
Scheduled Date/Time: 12/27/2018
Completed Date/Time: 12/27/2018
Inspector: Ken Slattum
Result: DISAPPROVED

Remarks:

Notes: Lock box code 5150

R15 insulation required in zone 4 Harnett County. Remove R13 and replace with R15.

Harnett C O U N T Y NORTH CAROLINA

Harnett County

108 EAST FRONT STREET

LILLINGTON, NC 27546

Phone: Fax:

Inspection Type: INSULATION
Scheduled Date/Time: 1/7/2019
Completed Date/Time: 1/7/2019
Inspector: Ken Slattum
Result: APPROVED

Remarks:

Notes: Lockbox#1020

Inspection Type: TEMP POWER CERTIFICATION

Scheduled Date/Time: 3/7/2019
Completed Date/Time: 3/7/2019
Inspector: Ken Slattum
Result: DISAPPROVED

Remarks:

Notes: Cannot have open wires hanging out of walls

Inspection Type: TEMP POWER CERTIFICATION

Scheduled Date/Time: 3/19/2019
Completed Date/Time: 3/19/2019
Inspector: Ken Slattum
Result: APPROVED

Remarks:

Notes: Lock box code is 1020

Inspection Type: FINAL**
Scheduled Date/Time: 4/2/2019 Any
Completed Date/Time: 4/2/2019
Inspector: Scott Guy
Result: APPROVED

Remarks: eTRAKiT Inspection Request

Notes: 4/1/2019 11:13 AM Josh Sturtz Homes

Lockbox Code 1020

Contact Name: Josh Sturtz Homes Site Address: 54 WILLIAM BETHUNE CT

Phone: 9107971695

e-Mail: teamsturtzy@gmail.com