## HTE# BORES 1810-0002 Harnett County Department of Public Health

Improvement Permit

A building permit cannot be issued with only an Improvement Permit
PROPERTY LOCATION: 155 Tyler Godwin Rd. (Old Stog Rd S.)
ISSUED TO: Paradise Homes SUBDIVISION Riverland Ests LOT # 27
NEW REPAIR EXPANSION Site Improvements required prior to Construction Authorization Issuance:
Type of Structure: 482 76 x 26 4" DWM+)
Proposed Wastewater System Type: 25% Nedwition Sys.
Projected Daily Flow: 486 GPD
Number of bedrooms: Number of Occupants: max
Basement Yes No
Pump Required:   Yes   No   May be required based on final location and elevations of facilities
Type of Water Supply:  Community Public Well Distance from well feet Permit valid for: Five years  Permit conditions:  No expiration
Permit conditions: No expiration
Authorized State Agent:: Carried State Agent: Date: 10115/2018 SEE ATTACHED SITE SKETCH
Authorized State Agent: SEE ATTACHED SITE SKETCH  The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This
site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of
the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.
Construction Authorization
(Required for Building Permit)
The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958 and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance
with the attached system layout.
ISSUED TO: Paradise Homes PROPERTY LOCATION: 155 Tyler Godwin Rd. (Oldster Rd.)
SUBDIVISION Rivertand Ests LOT # 27
Facility Type: LIBIL 76 × 264" DW D New Expansion Repair
Basement?  Yes No Basement Fixtures? Yes No
Type of Wastewater System** 25% Neduction System (Initial) Wastewater Flow: 480 GPD
(See note below, if applicable □)
25% Reduction Sys. (Repair)
Installation Requirements/Conditions  Number of trenches
Septic Tank Size 1000 gallons Exact length of each trench 60 feet Trench Spacing: 7 Feet on Center
Maximum Trench Depth of: 24 10 inches (Maximum soil cover shall not exceed
(Trench bottoms shall be level to $\pm 1/4$ " 36" above the trench bottom)
in all directions)
Pump Requirements:ft. TDH vs GPM inches below pipe
Aggregate Depth: NA inches above pipe
Conditions: Deep (24in) to Shallow (18in) install may be required No inches total
VATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA.
IO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA.
*If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.
Owner/Legal Representative Signature: Date:
his Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This
onstruction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit.
authorized State Agent: Date: 10/15/2018
AND Construction Authorization Expiration Date: 10/15/0003

HTE#	BRES	810-0	006
HIE#	TRES	800-0	(D)

Permit # 30199

## Harnett County Department of Public Health Site Sketch

ISSUED TO: Paradise Ho	PROPERTY LOCA  SUBDIVISIO	TON: 186 /yles	d Ests LOT# 27
Authorized State Agent:	ANDREW WRO	Date Date	10/15/2018
PROPERTY LINE SHALL BE CLIEARLY MARED BY SURVEYOR	47-60 (80 (80 ) 19 ) 19 1 15 1 15 1 15 1 15 1 15 1 15	TEDAIR 100'S	* NEEP (RHIN) TO SHALLOW (IBIN) INSTALL REQUIRED * NO PROPOSED DECK/PORCH * TANKS MAY NEED TO BE POSITIONED TO MEET SETBALKS
	TYLER CODWIG	s nos	

Department of Environment, Health and Natural Resources Division of Environmental Health On-Site Wastewater Section

## SOIL/SITE EVALUATION for ON-SITE WASTEWATER SYSTEM

Sheet:	
Property ID:	
Lot #:	000
File #:	1210
Code:	45101
BIL	

Owner: Judy Lolas Applicant: Poradize Homes Address: 155 Tyles Godo'n Date Evaluated: 10/12/2018	
Address: 155 Tyles Godo's Date Evaluated: 10/12/2018	
Proposed Facility: Design Flow (.1949): 4806 Property Size: Property Recorded:	
Location of Site: 430 DOWN Property Recorded:	
Water Supply: Public Individual Well Spring	Other
Evaluation Method: Auger Boring Pit Cut	
Type of Wastewater: Sewage Industrial Process Mixed	

P R O F I .1940			SOIL MORPHOLOGY OTHER .1941 PROFILE FACTORS						
L E #	Landscape Position/ Slope %	Horizon Depth (In.)	.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	Profile Class & LTAR
1	L 2-36	0-6	Cr 51	VA 354					PS
		6-44	ge su	r1 50		44			0.35
2,3	L23%	06	62 5L	VM 554					P5
		6-40	na su	F1 58	7.511.040"	40			0.35
4	L 4-5%	0-12	CZ 3L	Va 554					UPS
		12-28	BNSIL	F1 58	7.541/1027"	28			0.35
			8						
					,				

Description	Initial	Repair System	Other Factors (.1946):
	System		Site Classification (.1948): Unsuitable Provisionally Suitable
Available Space (.1945)	V		Evaluated By:
System Type(s)	25% MZ	50% POS	Others Present: Andrew Curring MEHS
Site LTAR	0.35	0.35	