

# Certificate of Completion

Owner Carl & Wendy Cummings Address Truway  
(MUST BE FILLED IN) (MAILING ADDRESS)

Contractor R L Vaughn Address Holly Springs  
(MAILING ADDRESS)

Location of Premises Knight Estates Lot A  
(SUBDIVISION, STREET OR ROAD NAME OR NUMBER, LOT NO.)  
off SR 1403

### Details of Septic Tank System


Kind of Material for Tank:  Concrete  Other \_\_\_\_\_

Size of Tank: Capacity 1000 Gallons

Subsurface Drainage Field No. of Ditches 3 Exact Length of each Ditch 100 Ft. Width of Ditches 3 Ft. Depth of Ditches 20-24 Inches

Square Feet in Absorption Field 900 Surface Drainage Required \_\_\_\_\_ Linear Ft.

Inspected by N L L (SANITARIAN) rs  
Date 6 Dec 91



# IMPROVEMENT PERMIT

Be It ordained by the Harnett County Board of Health as follows:  
Section III, Item B. "No person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department."

Name: (owner) Paul + Wendy Cummings  New Installation  Septic Tank  
 Property Location: off SR 1403  Repairs  Nitrification Line  
Knights Estates lot A

Number of Bedrooms Proposed: 3  Dish Washer  Garbage Disposal  
 Lot Size: 3.022 acres Water Supply:  Well  City  Community  
 Distance From Well?

Above information certified by: Application

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Kind of Material for Tank:  Concrete  Other \_\_\_\_\_

Size of Tank: Capacity 1000 Gallons


Subsurface No. of 3 Exact Length 100 Width of 3 Depth of 20 Inches  
 Drainage Field Ditches of each Ditch Ft. Ditches Ft. Ditches

Any Change in the layout of this system without prior approval of the issuing authority will result in this permit being void.

Date: 06/10/91  
Signed: Charles H. Hood Jr.  
(SANITARIAN)

Void After 5 Years

\* This permit is subject to revocation if site plans or intended use change.



→ SR 1403 to SR 1412 →