

October 25, 2018

Harnett County Government Complex  
307 W. Cornelius Harnett Boulevard  
Lillington, NC 27546

Rebecca Daniels  
49 Wallace Street  
Angier, NC 27501

ph: 910-893-7547  
fax: 910-893-9371

**RE: Harnett County Land Use Existing Tank Application #BRES 1810-0032  
49 Wallace Street – McAdams Acres**

Dear Mrs. Daniels,

The Harnett County Department of Public Health, Environmental Health Division evaluated the above referenced property at the site designated on the plat/site plan that accompanied your existing tank application. According to your application requesting, a 25x18 detached metal garage. The evaluation was done in accordance with the laws and rules governing wastewater systems in North Carolina General Statute 18A.1950 including related statutes and Title 15A, Subchapter 18A, of the North Carolina Administrative Code, Rule.1950 and related rules.

Based on the criteria set out in Title 15A, Subchapter 18A, of the North Carolina Administrative Code, Rules .1950, the evaluation indicated that the site is **UNSUITABLE** for. Therefore, your request for an existing tank is **DENIED**. The site is denied based on the following:

- \_\_\_\_\_ 15A NCAC 18A.1950a {16} - Any swimming pool must be 15' from any part of septic system.
- \_\_\_\_\_ 15A NCAC 18.1945{b} - Each lot shall have original septic system plus repair area.
- X   15A NCAC 18A.1950 {10} - Any building to be 5' from septic tank and/or from drain line.
- \_\_\_\_\_ 15A NCAC 18A.1950{c} - Nitrification fields and repair areas shall not be located under paved areas or areas subject to vehicular traffic.

**Proposed building on existing septic drain field. Concrete sanitary tee broken with replacement required. Septic drain lines flagged onsite. Proposed building shall be located off flagged system (7ft away min.). Revise paperwork and replace tee. Applicant notified onsite. Reconfirm when ready. No revision fee.**

Call me to discuss further the options that may be available to you. If you should have any questions or concerns, I can be contacted Monday through Friday from 8am – 9am at 910-893-7547.

Sincerely,



Andrew Currin, R.E.H.S.  
Environmental Health Specialist  
Harnett County Department of Public Health

AC/sgs