

Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: Mark Craft PROPERTY LOCATION: 126 Delany Cto (Suggs rd. SL 1727)
 NEW REPAIR EXPANSION SUBDIVISION: Watts Crossing LOT # 3
 Type of Structure: 3BR 28'x56' DUMH Site Improvements required prior to Construction Authorization Issuance:
 Proposed Wastewater System Type: 25% Redo Sys.
 Projected Daily Flow: 360 GPD
 Number of bedrooms: 3 Number of Occupants: 6 max
 Basement Yes No
 Pump Required: Yes No May be required based on final location and elevations of facilities
 Type of Water Supply: Community Public Well Distance from well 50+ feet (min) Permit valid for: Five years
 Permit conditions: _____ No expiration

Authorized State Agent: [Signature] Date: 11/02/2018 10/25/2018 SEE ATTACHED SITE SKETCH

The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: Mark Craft PROPERTY LOCATION: 126 Delany Cto (Suggs rd. SL 1727)
 Facility Type: 3BR 28'x56' DUMH New Expansion Repair
 Basement? Yes No Basement Fixtures? Yes No
 Type of Wastewater System** 25% Reduction System (Initial) Wastewater Flow: 360 GPD
 (See note below, if applicable)

Pump to 25% Redo Sys. (Repair)

Installation Requirements/Conditions	Number of trenches <u>3</u>	
Septic Tank Size <u>1000</u> gallons	Exact length of each trench <u>75</u> feet	Trench Spacing: <u>9</u> Feet on Center
Pump Tank Size _____ gallons	Trenches shall be installed on contour at a	Soil Cover: <u>16-10</u> inches
	Maximum Trench Depth of: <u>28-22</u> inches	(Maximum soil cover shall not exceed
	(Trench bottoms shall be level to +/-1/4"	36" above the trench bottom)
	in all directions)	
Pump Requirements: _____ ft. TDH vs. _____ GPM		<u>NA</u> inches below pipe
		Aggregate Depth: <u>NA</u> inches above pipe
Conditions: <u>Tight setbacks install. Use trench depth to install</u>		<u>NA</u> inches total
		<u>System tight to space</u>

**WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA.
 NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA.**

**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: _____ Date: _____

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH

Authorized State Agent: [Signature] Date: 11/2/2018
ANDREW WAIN Construction Authorization Expiration Date: 10/25/2020 11/2/2023

HTE# BRES1810-0034R

Permit # 30259

Harnett County Department of Public Health Site Sketch

ISSUED TO: Mark Craft PROPERTY LOCATION: 126 Delaney Ct. (Suggs Rd. 52 1727)
SUBDIVISION Wrights Crossing LOT # 3

Authorized State Agent: [Signature] Date: 11/02/2018 11/02/2018
ANDREW CURRIN

- * CONSULT PRIOR TO INSTALL MAY BE REQUIRED
- * DRAINFIELD WILL NEED TO BE INSTALLED TIGHT [40FT FRONT SETBACK]
 - 10FT EXACT OFF PROPERTY LINE
 - 5FT EXACT OFF STOOP
- * MARK WELL LOCATIONS AND ENSURE 50FT SETBACKS
- * USE TRENCH DEPTH FOR TIGHT INSTALL

