

**Improvement Permit**

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: Mark Craft PROPERTY LOCATION: 126 Delany Cto (Suggs rd. SR 1727)  
 NEW  REPAIR  EXPANSION  SUBDIVISION: Watts Crossing LOT # 3  
 Type of Structure: 3BR 28'x56' DUMH Site Improvements required prior to Construction Authorization Issuance:  
 Proposed Wastewater System Type: 25% Redo Sys.  
 Projected Daily Flow: 360 GPD  
 Number of bedrooms: 3 Number of Occupants: 6 max  
 Basement  Yes  No  
 Pump Required:  Yes  No  May be required based on final location and elevations of facilities  
 Type of Water Supply:  Community  Public  Well Distance from well 50+ feet (min)  
 Permit conditions: \_\_\_\_\_ Permit valid for:  Five years  No expiration

Authorized State Agent: Andrew Wain Date: 10/25/2018 SEE ATTACHED SITE SKETCH  
 The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

**Construction Authorization**

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: Mark Craft PROPERTY LOCATION: 126 Delany Cto (Suggs rd. SR 1727)  
 Facility Type: 3BR 28'x56' DUMH  New  Expansion  Repair  
 Basement?  Yes  No Basement Fixtures?  Yes  No  
 Type of Wastewater System\*\* 25% Reduction System (Initial) Wastewater Flow: 360 GPD  
 (See note below, if applicable )  
Pump to 25% Redo Sys. (Repair)  
**Installation Requirements/Conditions**  
 Septic Tank Size 1000 gallons Number of trenches 3  
 Pump Tank Size \_\_\_\_\_ gallons Exact length of each trench 75 feet Trench Spacing: 9 Feet on Center  
 Trenches shall be installed on contour at a Soil Cover: 16-10 inches  
 Maximum Trench Depth of: 28-22 inches (Maximum soil cover shall not exceed 36" above the trench bottom)  
 (Trench bottoms shall be level to +/-1/4" in all directions)  
 Pump Requirements: \_\_\_\_\_ ft. TDH vs. \_\_\_\_\_ GPM Aggregate Depth: NA inches below pipe  
 Conditions: Tight setbacks install. Use trench depth to install system tight to space NA inches above pipe  
NA inches total

**WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA.  
 NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA.**

\*\*If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: \_\_\_\_\_ Date: \_\_\_\_\_

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH

Authorized State Agent: Andrew Wain Date: 10/25/2018  
ANDREW WAIN Construction Authorization Expiration Date: 10/25/2020

HTE# BUES1810-0034

Permit # 30259

# Harnett County Department of Public Health Site Sketch

ISSUED TO: Mark Craft

PROPERTY LOCATION: 126 Delaney Ct. (Suggs Rd. SR 1727)  
SUBDIVISION Watts Crossing LOT # 3

Authorized State Agent: *Andrew Curran*  
ANDREW CURRAN

Date: 10/25/2018

- \*CONSULT PRIOR TO INSTALL MAY BE REQUIRED
- \*DRAINFIELD WILL NEED TO BE INSTALLED TIGHT (40FT FRONT SETBACK)
  - 10FT EXACT OFF PROPERTY LINE
  - 5FT EXACT OFF STOOP
- \*MARK WELL LOCATIONS AND ENSURE SOFT SETBACKS
- \*USE TRENCH DEPTH FOR TIGHT INSTALL



