

HTE #: BRES1810-0040

HARNETT COUNTY HEALTH DEPARTMENT  
ENVIRONMENTAL HEALTH  
307 CORNELIUS HARNETT BOULEVARD  
LILLINGTON, NC 27546

**EXISTING SEPTIC SYSTEM INSPECTION**

Name: Emma Taylor Phone #: 919.478.3799

Address: 2240 N. Bragg Blvd Spring Lake, NC 28390

Name of Mobile Home Park or S/D: NA

Name of Owner (if different): Marshall Taylor

Address of Owner (if different): 897 Old NC 87 Sanford, NC 27332

Property Location (State Road name and #): 851 Old NC 87 Sanford, NC 27332

Purpose of Inspection: MFH Single Wide (14'x60') - 2 bedrooms

Note: Proposed SWMH downhill from previous SWMH location. Septic pump system to existing septic system may be required if adequate plumbing fall cannot be maintained.


**The aforementioned site has been evaluated by the Harnett County Health Department Environmental Health Section. At the time of inspection, there appeared to be a septic system serving this site. If the system should malfunction, the owner is responsible for any necessary repairs.**

**THIS INSPECTION IS VOID IF:**

1. the intended use of the septic system should change, and/or
2. the system should fail or malfunction, and/or
3. the owner or tenant of the property change, and/or
4. after six months

**BUILDING MUST BE 5' FROM ANY PART OF SEPTIC SYSTEM  
DO NOT DRIVE OR PARK ON SEPTIC SYSTEM**

AUTHORIZATION OF EXISTING SYSTEM

  
Signature of Environmental Health Specialist

11/01/2018  
Date