

November 26, 2018

Harnett County Government Complex
307 W. Cornelius Harnett Boulevard
Lillington, NC 27546

Mistianne Jacobs
1885 Mabry Road
Angier, NC 27501

ph: 910-893-7547
fax: 910-893-9371

Re: Status of Improvement Permit Application BRES #1810-0042

Dear Ms. Jacobs,

An attempt was made to evaluate your property for the purpose of issuing an Improvement Permit. The evaluation could not be completed for one or more of the following reasons.

- 1. Use pink flags to mark property lines and irons that are set by surveyor need to be visible *(\$25.00 fee incurred)*
- 2. Use orange flags to mark house corners *(\$25.00 fee incurred)*
- 3. Directions not clear to property *(\$25.00 fee incurred)*
- 4. Property needs only brush or vegetation removed
- 5. Driveway not shown on site plan
- 6. Backhoe pits required
- 7. Other – Proposed mobile home is located over existing drain line. Proposed mobile home location shall not be located on existing septic area. A new proposed location is required. The 90 feet power easement shall be marked by surveyor for final permitting. Adequate septic area and septic repair will be required for the existing singlewide mobile home and the proposed mobile home.**

Your application will be put on hold until the selected items above have been addressed. When completed **please call 910-893-7547 to confirm** that the items mentioned have been corrected. We will then reschedule your property for evaluation.

Sincerely,



Andrew Currin, R.E.H.S.
Environmental Health Specialist
Harnett County Department of Public Health

AC/sgs
Copy: Central Permitting