

Improvement Permit

Ronald Pegues (owner)
 ISSUED TO: David Andersson (GoCo) PROPERTY LOCATION: 232 Wexford Dr. (Purfoy Road) SR 1446
 SUBDIVISION: Wexford S/D LOT # 12
 NEW REPAIR EXPANSION
 Type of Structure: 2BL S/D (EXT) → 3BL S/D
 Proposed Wastewater System Type: Conventional 25% Redo
 Projected Daily Flow: 360 GPD
 Number of bedrooms: 3 Number of Occupants: 6 max
 Basement Yes No
 Pump Required: Yes No May be required based on final location and elevations of facilities
 Type of Water Supply: Community Public Well Distance from well NA feet Permit valid for: Five years
 Permit conditions: _____ No expiration

Authorized State Agent: [Signature] Date: 11/30/2018 SEE ATTACHED SITE SKETCH
 The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

Ronald Pegues (owner)
 ISSUED TO: David Andersson (GoCo) PROPERTY LOCATION: 232 Wexford Dr. (Purfoy Road) SR 1446
 SUBDIVISION: Wexford S/D LOT # 12
 Facility Type: 2BL S/D (EXT) → 3BL S/D New Expansion Repair
 Basement? Yes No Basement Fixtures? Yes No
 Type of Wastewater System** Conventional & 25% Redo Sys. (Initial) Wastewater Flow: 360 GPD
 (See note below, if applicable 25% Reduction Sys. (Repair))

Installation Requirements/Conditions

Septic Tank Size <u>Ext</u> gallons	Number of trenches <u>1 (NEW)</u>	Trench Spacing: <u>9</u> Feet on Center
Pump Tank Size _____ gallons	Exact length of each trench <u>75 (NEW)</u> feet	Soil Cover: <u>6+</u> inches
	Trenches shall be installed on contour at a Maximum Trench Depth of: <u>28</u> inches	(Maximum soil cover shall not exceed 36" above the trench bottom)
	(Trench bottoms shall be level to +/-1/4" in all directions)	
Pump Requirements: _____ ft. TDH vs. _____ GPM	Aggregate Depth: <u>NA</u> inches below pipe	<u>NA</u> inches above pipe
Conditions: <u>Meet onsite required; Polo & Utilities shall be clearly marked at install</u>		<u>NA</u> inches total

WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA. NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA.

**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: _____ Date: _____

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH

Authorized State Agent: [Signature] Date: 11/30/2018
ANDREW WRAIN Construction Authorization Expiration Date: 11/30/2023

HTE# BRES1811-0002

Permit # 30286

Harnett County Department of Public Health Site Sketch

52 1446

Ronald Pegues (owner)

PROPERTY LOCATOR: 232 Wexford Dr. (Purfoy Road)

ISSUED TO: David Anderson (contractor)

SUBDIVISION Wexford SID

LOT # 12

Authorized State Agent:

Andrew Curran

Date: 11/30/2018

ANDREW CURRAN

