

Application # BRES1811-0008
BRES1811-0007

Harnett County Central Permitting
PO Box 65 Lillington, NC 27546 - Ph: 910-893-7525 - Fx: 910-893-2793 - www.harnett.org/permits
Certification of Work Performed By Owner/Contractor
(Individual Trade Application)

Owner (s) of Structure: BRENDA McELVEEN Phone (910) 728-7228

Owner (s) Mailing Address: 322 Valerie Lane
Linden, N.C 28356

Land Owner Name (s): Brenda McElveen Phone: (910) 728-7228

Construction or Site Address: 322 Valerie Lane Linden, N.C 28356

PIN # _____ Parcel # _____

Job Cost: _____ Description of Work to be done rewiring building

Mechanical: New Unit With Ductwork ___ New Unit Without Ductwork ___ Gas Piping ___ Other ___

Electrical*: 200 Amp ___ <200 Amp ___ Service Change ___ Service Reconnect ___ Other ___
* For Progress Energy customers we need the premise number

Plumbing: Water/Sewer Tap ___ Number of Baths ___ Water Heater ___

Specific Directions to Job from Lillington:

Subdivision: _____ Lot #: _____

I Brandon Lee will provide the rewiring building labor on this structure.
(Contractors Name) (Trade)

I am the building owner or my NC state license number is _____, which entitles me to perform such work on the above structure legally. All work shall comply with the State Building Code and all other applicable State and local laws, ordinances and regulations.

Brandon Lee Electric
Contractor's Company Name

(910) 709-7896
Telephone

1115 Jonesboro Road Dunn NC 28334
Address

Email Address

29333 L
License #

Structure Owner / Contractor Signature: Brenda McElveen Date 11/5/2018

By signing this application you affirm that you have obtained permission from the above listed license holder to purchase permits on their behalf. If doing the work as owner you understand that you cannot rent, lease or sell the listed property for 12 months after completion of the listed work.

***Company name, address, & phone must match information on license**

CATO ENGINEERING ASSOCIATES

3520 Carolyn Drive, Raleigh, North Carolina 27604-1614

Office 919-876-3972*****Cell 919-971-2392

October 22, 2018

CEI Job No: 8BDG

Mrs. Brenda McElvin

322 Valerie Lane

Linden, NC 28356

Re: Structural investigation of a recreational building which used to be a garage for a single-wide mobile home located at 322 Valerie Lane in Linden, Harnett County, North Carolina 28356.

Dear Mrs. McElvin,

The single-wide mobile home is being demolished. The electrical service should be terminated into a meter and lockable panel box on the outside of the building. It shall be ran inside for water heater and lights. Plumbing shall be for small bathroom in recreational building. It shall be winterized for cold weather. By observation and study of the damage site, I have determined that the structure roof should have a new treated 2x4 bottom chord from wall to wall. It should have diagonal bracing to the existing bottom chord. With this the building will carry the wind and gravity loads pursuant to the NCRC.

I certify that the above building is ready for the necessary flood restoration procedure. I will return to check any part that the Code Enforcement Official requests that I check. This will be at no charge to you.

Kindest regards,

CATO ENGINEERING ASSOCIATES, pllc

J. C. "Chuck" Cato, P.E.

President

