

HTE# Bas 811-0011

HARNETT COUNTY HEALTH DEPARTMENT  
ENVIRONMENTAL HEALTH  
307 CORNELIUS HARNETT BOULEVARD  
LILLINGTON, NC 27546

EXISTING SEPTIC SYSTEM INSPECTION

NAME: Betty Baker PHONE # 910 797 9532

ADDRESS 4566 Broadway Rd Sanford N.C. 27330

NAME OF MOBILE HOME PARK OR S/D \_\_\_\_\_

NAME OF OWNER (IF DIFFERENT) Wilbur Thomas

ADDRESS OF OWNER (IF DIFFERENT) 910 Broadway Rd Sanford N.C.

PROPERTY LOCATION: STATE ROAD NAME AND # SR 1222 Broadway Rd

PURPOSE OF INSPECTION: Replace SNAIT

The aforementioned site has been evaluated by the Harnett County Health Department Environmental Health Section. At the time of inspection, there appeared to be a septic system serving this site. If this system should malfunction, the owner is responsible for any necessary repairs.

THIS INSPECTION IS VOID IF:

- (1) the intended use of the septic system should change, and/or
- (2) the system should fail or malfunction, and/or
- (3) the owner or tenant of the property changes, and/or
- (4) after six months

**BUILDING MUST BE 5' FROM ANY PART OF SEPTIC SYSTEM  
DO NOT DRIVE OR PARK ON SEPTIC SYSTEM**

AUTHORIZATION OF EXISTING SYSTEM

James E. Mashan  
Signature of Environmental Health Specialist

11-20-18

Date