



Harnett County
108 EAST FRONT STREET
LILLINGTON, NC 27546
Phone:
Fax:

1/10/2020

SUBJECT: BRES1811-0034
BUILDING RESIDENTIAL

To: CHOO'S MOBILE HOME TRANSIT

Here are the results of all Inspections located at **11 JOEY DR:**

Inspection Type: ADDRESS
Scheduled Date/Time:
Completed Date/Time:
Inspector: GIS Bucket
Result:
Remarks:
Notes:

Inspection Type: ZONING
Scheduled Date/Time:
Completed Date/Time:
Inspector: Planning Bucket
Result:
Remarks:
Notes:

Inspection Type: FINAL**
Scheduled Date/Time:
Completed Date/Time:
Inspector: Ray Holder
Result:
Remarks:
Notes:

Inspection Type: MH FOUND/MARRIAGE WALL
Scheduled Date/Time:
Completed Date/Time:
Inspector: Deen Taylor
Result:
Remarks:
Notes:



Harnett County
108 EAST FRONT STREET

LILLINGTON, NC 27546

Phone:

Fax:

Inspection Type: MH FOUND/MARRIAGE WALL

Scheduled Date/Time: 12/23/2019

Completed Date/Time: 12/23/2019

Inspector: Steven Gazlay

Result: DISAPPROVED

Remarks:

Notes:

Inspector RLH changed the inspection assignment from RLH to SPG

No plumbing drain test. Electrical meter base and service to panel not installed. Vapor barrier not completed. Insulate water line and expansion tank.