

BRES1811-0039

Application # EPRES1811-0036

MPRES1811-0023

IPRES1811-0007

Harnett County Central Permitting
PO Box 65 Lillington, NC 27546
910-893-7525 Fax 910-893-2793 www.harnett.org/permits

* Each section below to be filled out by whomever performing work. Must be owner or licensed contractor. Address, company name & phone must match

Application for Residential Building and Trades Permit

Owner's Name: Joshua Kelly Date: 11/26/18
Site Address: 670 Valerie Lane Gnden 28356 Phone: 910-568-6094
Directions to job site from Lillington: _____

Subdivision: PIN 0554-59-9160.000 P/D 1205550152 Lot: _____

Description of Proposed Work: _____ # of Bedrooms: _____
Heated SF: _____ Unheated SF: _____ Finished Bonus Room? _____ Crawl Space: _____ Slab: _____

General Contractor Information

~~Owner~~ Building Contractor's Company Name: Dawn Kelly Telephone: 910-354-7705
Address: _____ Email Address: thefirstplowelady@yahoo.com
License #: _____

Electrical Contractor Information

Description of Work: _____ Service Size: _____ Amps T-Pole: _____ Yes _____ No
Electrical Contractor's Company Name: Brandon Lee Electric Telephone: 910 709-7896
Address: _____ Email Address: _____
License #: 29333

Must be licensed

Mechanical/HVAC Contractor Information

Description of Work: ~~OWNER~~ HVAC
Mechanical Contractor's Company Name: AC NOW (Jamie Bowden) Telephone: 910 822-4294
Address: _____ Email Address: _____
License #: 19660

Must be licensed

Plumbing Contractor Information

Description of Work: _____ # Baths: _____
Plumbing Contractor's Company Name: _____ Telephone: _____
Address: _____ Email Address: _____
License #: _____

Insulation Contractor Information

Insulation Contractor's Company Name & Address: OWNER Telephone: _____

*NOTE: General Contractor / owner must fill out and sign the second page of this application.

1 ACC-11, 2018
2000-10, 2018

I hereby certify that I have the authority to make necessary application, that the application is correct and that the construction will conform to the regulations in the Building, Electrical, Plumbing and Mechanical codes, and the Harnett County Zoning Ordinance. I state the information on the above contractors is correct as known to me and that **by signing below I have obtained all subcontractors permission to obtain these permits** and if **any** changes occur including listed contractors, site plan, number of bedrooms, building and trade plans, Environmental Health permit changes or proposed use changes, I certify it is my responsibility to notify the Harnett County Central Permitting Department of any and all changes.

EXPIRED PERMIT FEES - 6 Months to 2 years permit re-issue fee is \$150.00. After 2 years re-issue fee is as per current fee schedule.


Signature of Owner/Contractor/Officer(s) of Corporation

11/26/18
Date

Affidavit for Worker's Compensation N.C.G.S. 87-14

The undersigned applicant being the:

General Contractor Owner Officer/Agent of the Contractor or Owner

Do hereby confirm under penalties of perjury that the person(s), firm(s) or corporation(s) performing the work set forth in the permit:

Has three (3) or more employees and has obtained workers' compensation insurance to cover them.

Has one (1) or more subcontractors(s) and has obtained workers' compensation insurance to cover them.

Has one (1) or more subcontractors(s) who has their own policy of workers' compensation insurance covering themselves.

Has no more than two (2) employees and no subcontractors.

While working on the project for which this permit is sought it is understood that the Central Permitting Department issuing the permit may require certificates of coverage of worker's compensation insurance prior to issuance of the permit and at any time during the permitted work from any person, firm or corporation carrying out the work.

Company or Name: _____

Sign w/Title: _____ Date: _____

CATO ENGINEERING ASSOCIATES

3520 Carolyn Drive, Raleigh, North Carolina 27604-1614

Office 919-876-3972*****Cell 919-971-2392

October 22, 2018

CEI Job No: 8BDE

Mrs. Dawn Kelly

670 Valerie Lane

Linden, NC 28356

Re: Structural investigation of a single-family double-wide mobile home with HUD labile No's (f) TRA 307110 and (b) TRA 307109 located at 670 Valerie Lane in Linden, Harnett County, North Carolina 28356.

Dear Mrs. Kelly,

By observation and study of the damage site, I have determined that the structure will carry the wind and gravity loads pursuant to the NCRC. The subfloor was removed. The walls were gutted to well above the water line. The plumbing was not damaged. The electrical should be restored by a licensed electrician.

I certify that the above home is ready for the necessary flood restoration procedure. I will return to check any part that the Code Enforcement Official requests that I check. This will be at no charge to you.

Kindest regards,

CATO ENGINEERING ASSOCIATES, pllc

J. C. "Chuck" Cato, P.E.

President

