

HTE# \_\_\_\_\_

HARNETT COUNTY HEALTH DEPARTMENT  
ENVIRONMENTAL HEALTH  
307 CORNELIUS HARNETT BOULEVARD  
LILLINGTON, NC 27546

EXISTING SEPTIC SYSTEM INSPECTION

NAME: Sam Myers PHONE # 919-302-2347

ADDRESS 516 Ruth Circle FV. N.C. 27526

NAME OF MOBILE HOME PARK OR S/D Belland Woods lot 56

NAME OF OWNER (IF DIFFERENT) \_\_\_\_\_

ADDRESS OF OWNER (IF DIFFERENT) \_\_\_\_\_

PROPERTY LOCATION: STATE ROAD NAME AND # 12x28 SHED

**PURPOSE OF INSPECTION:**

The aforementioned site has been evaluated by the Harnett County Health Department Environmental Health Section. At the time of inspection, there appeared to be a septic system serving this site. If this system should malfunction, the owner is responsible for any necessary repairs.

**THIS INSPECTION IS VOID IF:**

- (1) the intended use of the septic system should change, and/or
- (2) the system should fail or malfunction, and/or
- (3) the owner or tenant of the property changes, and/or
- (4) after six months

**BUILDING MUST BE 5' FROM ANY PART OF SEPTIC SYSTEM  
DO NOT DRIVE OR PARK ON SEPTIC SYSTEM**

**AUTHORIZATION OF EXISTING SYSTEM**

James E. Monahan JR RBHS  
Signature of Environmental Health Specialist

12-12-18  
Date