

HTE# _____

HARNETT COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH
307 CORNELIUS HARNETT BOULEVARD
LILLINGTON, NC 27546

EXISTING SEPTIC SYSTEM INSPECTION

NAME: Matthew Smith PHONE # 919-600-9812
919-628-5345

ADDRESS 170 Clover Ridge Angier N.C. 27501

NAME OF MOBILE HOME PARK OR S/D Neells Creek Farms W/HD

NAME OF OWNER (IF DIFFERENT) _____

ADDRESS OF OWNER (IF DIFFERENT) _____

PROPERTY LOCATION: STATE ROAD NAME AND # SR 1440 James Norris Rd

PURPOSE OF INSPECTION: 21X24 GARAGE
The aforementioned site has been evaluated by the Harnett County Health Department Environmental Health Section. At the time of inspection, there appeared to be a septic system serving this site. If this system should malfunction, the owner is responsible for any necessary repairs.

- THIS INSPECTION IS VOID IF:**
- (1) the intended use of the septic system should change, and/or
 - (2) the system should fail or malfunction, and/or
 - (3) the owner or tenant of the property changes, and/or
 - (4) after six months

**BUILDING MUST BE 5' FROM ANY PART OF SEPTIC SYSTEM
DO NOT DRIVE OR PARK ON SEPTIC SYSTEM**

AUTHORIZATION OF EXISTING SYSTEM

James E. Manhart REHS 12-6-18
Signature of Environmental Health Specialist Date