

HARNETT COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH SECTION

HTE 04-5-9779

17339

OPERATIONS PERMIT

Name: (owner) William Jeffrey Weeks

New Installation Septic Tank

Property Location: SR# 2061

Repairs Nitrification Line

Subdivision _____

Lot # _____

Tax ID # _____

Quadrant # _____

Contractor: Gerald Temple

Registration # _____

Basement with Plumbing: Garage:

Water Supply: Well Public Community

Distance From Well: 50 ft.

Following are the specifications for the sewage disposal system on above captioned property.

Type of system: Conventional Other _____

Size of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallons


Subsurface Drainage Field No. of ditches 3 exact length of each ditch 100 ft. width of ditches 3 ft. depth of ditches 24-30 in.

French Drain Required: _____ Linear feet

Date: 6/30/2004

Inspected by: [Signature]
Environmental Health Specialist

PERMIT NO. 20530



HARNETT COUNTY HEALTH DEPARTMENT

HTE 04-5-9779

IMPROVEMENT PERMIT

20530

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No Person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department."

Name: (owner) William Jeffery Weeks New Installation Septic Tank
Property Location: SR# 2061 Russ Rd Repairs Nitrification Line

Subdivision _____ Lot # _____

Tax ID # _____ Quadrant # _____

Number of Bedrooms Proposed: 3 Lot Size: 19.15 Ac

Basement with Plumbing: Garage:

Water Supply: Well Public Community

Distance From Well: 50 ft.

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system: Conventional Other _____

Size of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallons

Subsurface Drainage Field No. of ditches 3 exact length of each ditch 80 ft. width of ditches 3 ft. depth of ditches 18-26 in.

French Drain Required: _____ Linear feet

Date: 6/28/2004

This permit is subject to revocation if site plans or intended use change.

Signed: [Signature]
Environmental Health Specialist

