

**Jennifer Brock**

---

**From:** fhogan@bramblebuilders.com  
**Sent:** Monday, May 13, 2019 11:33 AM  
**To:** Jennifer Brock  
**Subject:** FW: 81 Expedition Drive

**From:** JAMESHAYESHEATAC <jameshayesheatac@gmail.com>  
**Sent:** Friday, May 10, 2019 9:17 AM  
**To:** FHOGAN@bramblebuilders.com  
**Subject:** 81 Expedition Drive

**James Hayes Heating and AC, Inc.**

5349 South Forty Drive  
Hope Mills, NC 28348  
910-484-7155  
910-835-0053 (Fax)  
NC License #20051 H3-C1  
SC License #M104091 Pk2

May 10, 2019

To: Frank  
Bramble Builders

RE: 81 Expedition Drive  
Cameron, NC 28326

Total Sq Ft.	1687
Garage	<u>288</u>
Heated Sq Ft.	1399
Added Room	<u>144</u>
New Heated Sq. Ft.	1543

From the information given to me with the house at 1,543 square foot, the Lennox 2.5-ton equipment (Model #14HPX030 230-18 and serial #1912G11470) should be sufficient to condition 1,543 square foot heated space.

Thank you,

James B Hayes, Jr