



Harnett County
108 EAST FRONT STREET
LILLINGTON, NC 27546
Phone:
Fax:

9/26/2019

SUBJECT: BRES1901-0032
BUILDING RESIDENTIAL

To: MOSS KENNETH A

Here are the results of all Inspections located at **93 JOEL WAY:**

Inspection Type: MONO SLAB
Scheduled Date/Time:
Completed Date/Time:
Inspector: Scott Guy
Result:
Remarks:
Notes:

Inspection Type: SLAB
Scheduled Date/Time:
Completed Date/Time:
Inspector: Scott Guy
Result:
Remarks:
Notes:

Inspection Type: TAX INSPECTION
Scheduled Date/Time:
Completed Date/Time:
Inspector: Tax Inspection
Result:
Remarks:
Notes:

Inspection Type: ROUGH IN
Scheduled Date/Time:
Completed Date/Time:
Inspector: Scott Guy
Result:
Remarks:
Notes:



Harnett County
108 EAST FRONT STREET
LILLINGTON, NC 27546
Phone:
Fax:

Inspection Type: FOOTING
Scheduled Date/Time: 5/1/2019
Completed Date/Time: 5/1/2019
Inspector: Scott Guy
Result: APPROVED
Remarks:
Notes:

Inspection Type: FOUNDATION
Scheduled Date/Time: 5/15/2019
Completed Date/Time: 5/15/2019
Inspector: Scott Guy
Result: APPROVED
Remarks:
Notes:

Inspection Type: ROUGH IN
Scheduled Date/Time: 7/25/2019
Completed Date/Time: 7/25/2019
Inspector: Slade Burton Lawson III
Result: DISAPPROVED
Remarks:
Notes:

Inspector TSG changed the inspection assignment from TSG to SBL
Nail both sides stud columns below triple girders 12" oc . Strap stud columns both sides garage doors 2" square washers in wing wall and wall left of door Add anchor bolt rear wall left side Proper nail pattern on triple girder both sides Left side truss next to triple girder needs hurricane strap. Unable to locate Uplift information for triple girders. Verify no strapping needed Need taller ladder to access second floor for inspection Add king stud both sides garage door

Inspection Type: FINAL**
Scheduled Date/Time: 9/26/2019
Completed Date/Time: 9/26/2019
Inspector: Scott Guy
Result: APPROVED
Remarks:
Notes:





Harnett County
108 EAST FRONT STREET

LILLINGTON, NC 27546

Phone:

Fax:

Inspection Type: ROUGH IN
Scheduled Date/Time: 9/26/2019
Completed Date/Time: 9/26/2019
Inspector: Scott Guy
Result: APPROVED
Remarks:
Notes: