

February 25th, 2019

Humberto Morales
10 High Standard Lane
Angier, NC 27501

RE: Existing Tank Application # BRES1902-0023

Mr. Morales,

An attempt was made to evaluate your property for the purpose of issuing an existing tank permit. The evaluation could not be completed for one or more of the following reasons.

___ 1. Uncover Outlet lid on septic tank and break seal (\$25.00 fee incurred)

___ 2. Have system pumped out

___ 3. Replace Sanitary T

X 4. Other – **Proposed deck expansion within 5ft septic setbacks. Deck shall be shifted 2 feet away from tank to accommodate proposed deck. Revise paperwork and reconfirm with EH.**

Your application will be put on hold until the selected items above have been addressed.

When completed **call 893-7547 to confirm** that the items mentioned have been corrected, we will then reschedule your property for evaluation.

Sincerely,



Andrew Currin, R.E.H.S
Environmental Health Specialist
Harnett County Department of Public Health

AC/kh
Copy - Central Permitting