

**Improvement Permit**

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: PLTS Properties LLC PROPERTY LOCATION: Hwy 42 SUBDIVISION \_\_\_\_\_ LOT # \_\_\_\_\_

NEW  REPAIR  EXPANSION  Type of Structure: DWMT Site Improvements required prior to Construction Authorization Issuance: \_\_\_\_\_

Proposed Wastewater System Type: 25% RESTORATION (ACCEPTED)

Projected Daily Flow: 480 GPD

Number of bedrooms: 4 Number of Occupants: 8 max

Basement  Yes  No

Pump Required:  Yes  No  May be required based on final location and elevations of facilities

Type of Water Supply:  Community  Public  Well Distance from well \_\_\_\_\_ feet Permit valid for:  Five years  No expiration

Permit conditions: \_\_\_\_\_

Authorized State Agent: James E. Markham Date: 7-16-19 SEE ATTACHED SITE SKETCH

The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

**Construction Authorization**

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: PLTS Properties PROPERTY LOCATION: Hwy 42 SUBDIVISION \_\_\_\_\_ LOT # \_\_\_\_\_

Facility Type: DWMT  New  Expansion  Repair

Basement?  Yes  No Basement Fixtures?  Yes  No

Type of Wastewater System\*\* 25% RESTORATION SYSTEM (Initial) Wastewater Flow: 480 GPD

(See note below, if applicable  25% RESTORATION (Repair))

**Installation Requirements/Conditions**

Septic Tank Size 1200 gallons Number of trenches 4

Pump Tank Size \_\_\_\_\_ gallons Exact length of each trench 100 feet Trench Spacing: 7 Feet on Center

Trenches shall be installed on contour at a Maximum Trench Depth of: 12 max inches (Maximum soil cover shall not exceed 36" above the trench bottom)

(Trench bottoms shall be level to +/-1/4" in all directions)

Pump Requirements: \_\_\_\_\_ ft. TDH vs. \_\_\_\_\_ GPM Aggregate Depth: 10 inches below pipe 2 inches above pipe 12 inches total

Conditions: 6" of Fill REQUESTED

**WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA.**  
**NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA.**

\*\*If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: \_\_\_\_\_ Date: \_\_\_\_\_

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH

Authorized State Agent: James E. Markham Date: 7-16-19  
 Construction Authorization Expiration Date: 7-16-24

HTE# BZES1902-0030


Permit # 30534

# Harnett County Department of Public Health Site Sketch

ISSUED TO: PLIS Properties LLC PROPERTY LOCATOR: Hwy 42 SUBDIVISION \_\_\_\_\_ LOT # \_\_\_\_\_

Authorized State Agent: James E. Markham <sup>APRENS</sup> Date: 7-16-15

- \* NO WATER OR POWER LINES IN SYSTEM OR REPAIR AREA.
- \* 12" SYSTEM (AT GRADE) 6" OF COVER REQUIRED
- \* STAY 5' MINIMUM OFF OF ANY PART OF HOME STRUCTURE
- \* DRAWING IS REPRESENTATION OF LAYOUT - ALL ON SETC RULES TO BE FOLLOWED ON INSTALLATION.



Hwy 42