

HTE# 1903-0002

HARNETT COUNTY HEALTH DEPARTMENT  
ENVIRONMENTAL HEALTH  
307 CORNELIUS HARNETT BOULEVARD  
LILLINGTON, NC 27546

EXISTING SEPTIC SYSTEM INSPECTION

NAME: BIM BUIDERS PHONE # 919-524-5852

ADDRESS 6187 NC 27 E Coats N.C. 27521

NAME OF MOBILE HOME PARK OR S/D \_\_\_\_\_

NAME OF OWNER (IF DIFFERENT) Claire + Kathy Johnson

ADDRESS OF OWNER (IF DIFFERENT) 3955 Hwy 55 Angier N.C. 27821

PROPERTY LOCATION: STATE ROAD NAME AND # Hwy 55

PURPOSE OF INSPECTION: 21x26 GARAGE

The aforementioned site has been evaluated by the Harnett County Health Department Environmental Health Section. At the time of inspection, there appeared to be a septic system serving this site. If this system should malfunction, the owner is responsible for any necessary repairs.

THIS INSPECTION IS VOID IF:

- (1) the intended use of the septic system should change, and/or
- (2) the system should fail or malfunction, and/or
- (3) the owner or tenant of the property changes, and/or
- (4) after six months

BUILDING MUST BE 5' FROM ANY PART OF SEPTIC SYSTEM  
DO NOT DRIVE OR PARK ON SEPTIC SYSTEM

AUTHORIZATION OF EXISTING SYSTEM

[Signature]  
Signature of Environmental Health Specialist

3-19-19  
Date