Authorized State Agent:

ANDREW CURLIN

## HTE# BRE51903-0026 Harnett County Department of Public Health

30500

Improvement Permit 51174 A building permit cannot be issued with only an Improvement Permit Daniel Buckeral PROPERTY LOCATION:\_\_\_\_\_\_ ISSUED TO: SUBDIVISION NEW 🖵 Site Improvements required prior to Construction Authorization Issuance: Type of Structure: 3001 76'x16' SUSMA Proposed Wastewater System Type: 25% reduction Projected Daily Flow: 366 GPD Number of Occupants: \_ C max Number of bedrooms: Basement Yes Pump Required: ☐Yes ☐ No May be required based on final location and elevations of facilities Type of Water Supply: 

Community Public Well Distance from well 100 feet Permit valid for: 4. Five years ■ No expiration Permit conditions: Authorized State Agent:: Date: Date: Date: Date: SEE ATTACHED SITE SKETCH
The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit. **Construction Authorization** (Required for Building Permit) The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout. ISSUED TO: Daniel Bixhonan PROPERTY LOCATION: Black Lone (Mclean 12 5/1299)
SIBDIVISION LOT # ☐ Expansion ☐ Repair Basement Fixtures? | Yes | No | Reduction System (Initial) Wastewater Flow: 360 GPD Basement? Yes • No Type of Wastewater System\*\* (See note below, if applicable □) Installation Requirements/Conditions Septic Tank Size 1000 gallons Trenches shall be installed on contour at a Pump Tank Size \_\_\_\_\_ gallons Maximum Trench Depth of: \_\_\_\_ 24 \_\_\_ inches (Maximum soil cover shall not exceed (Trench bottoms shall be level to +/-1/4" 36" above the trench bottom) in all directions) Pump Requirements: \_\_\_\_\_ft. TDH vs. \_\_\_\_ GPM inches below pipe inches above pipe Aggregate Depth: inches total WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA. NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA. \*\*If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit. Owner/Legal Representative Signature: \_ This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This SEE ATTACHED SITE SKETCH Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. Date: \_\_\_\_\_ 04/01/2019

Construction Authorization Expiration Date: \_O4/d1/2024

HTE# BRES1963-0026

Permit # \_\_\_\_\_ 30.500

## Harnett County Department of Public Health Site Sketch

		510 1299
	PROPERTY LOCATON:	Black Lo. (McLean Rd.)
15SUED TO: Daniel Buchanan	SUBDIVISION	LOT #
Authorized State Agent:	a Campetts	Date:04/01/2019
AND	TEN CURNIN	

