

Harnett County 420 Mckinney Pkwy

LILLINGTON,NC 27546 Phone: Fax:

1/2/2025

## SUBJECT: BRES1903-0044 BUILDING RESIDENTIAL

To: Paul Mason

Here are the results of all Inspections located at **318 LLOYD STEWART RD**:

Inspection Type: Scheduled Date/Time: Completed Date/Time: Inspector: Result: Remarks: Notes:	FINAL** Scott Guy
Inspection Type: Scheduled Date/Time: Completed Date/Time:	FOUNDATION
Inspector: Result: Remarks: Notes:	Scott Guy
Inspection Type: Scheduled Date/Time: Completed Date/Time:	MONO SLAB
Inspector: Result: Remarks:	Scott Guy
Notes:	
Notes: Inspection Type: Scheduled Date/Time: Completed Date/Time:	SLAB



		<b>t County</b> kinney Pkwy	
NORTH CAROLINA	LILLING Phone: Fax:	TON,NC 27546	
Inspection Type Scheduled Date, Completed Date Inspector: Result: Remarks: Notes:	/Time:	ROUGH IN Scott Guy	
Inspection Type Scheduled Date, Completed Date	/Time:	FOOTING	
Inspector: Result:		Scott Guy	
Remarks: Notes:		eTRAKiT Inspection Request	
Inspection Type Scheduled Date, Completed Date Inspector: Result: Remarks: Notes:	/Time:	ROUGH IN 4/29/2019 4/29/2019 Scott Guy DISAPPROVED 1- slab prep not ready. 2- existing concrete pad area to be used as a footer requires an engineer. 3- back fill of pad requires a compaction letter.	
Inspection Type Scheduled Date, Completed Date Inspector: Result: Remarks: Notes:	/Time:	FOOTING 5/9/2019 5/9/2019 Scott Guy DISAPPROVED eTRAKIT Inspection Request 5/8/2019 10:46 AM Paul Mason	
		Contact Name: Paul Mason Site Address: 318 LLOYD STEWART RD Phone: 9105142146 e-Mail: windsor396@hotmail.com	
		1- need compaction letter. 2- need engineer letter for existing slab . 3- footings must be min 1	

1- need compaction letter. 2- need engineer letter for existing slab . 3- footings must be min 12 below grade 4- all rebar connections must lap 24" and radius in corners where required.



Harnett NORTH CAROLINA Harnett County 420 Mckinney Pkwy

LILLINGTON,NC 27546 Phone: Fax:

Inspection Type:	FOOTING
Scheduled Date/Time:	5/10/2019
Completed Date/Time:	5/10/2019
Inspector:	Scott Guy
Result:	APPROVED
Remarks:	eTRAKiT Inspection Request
Notes:	5/9/2019 11:43 AM Paul Mason The letter from the engineer had been emailed to MRS Gibbons on Tuesday May 5, 2019. The other issues WILL be dealt with by tomorrow morning. Thank you and I apologize. Contact Name: Paul Mason Site Address: 318 LLOYD STEWART RD Phone: 9105142146 e-Mail: windsor396@hotmail.com