

April 15th, 2019

Kevin Burris  
59 Spruce Lane  
Lillington, NC 27546

**RE: Existing Tank Application # BRES1903-0062**

Mr. Burris,

An attempt was made to evaluate your property for the purpose of issuing an existing tank permit. The evaluation could not be completed for one or more of the following reasons.

1. Uncover Outlet lid on septic tank and break seal (\$25.00 fee incurred).

2. Have system pumped out

3. Replace Sanitary T

**4. Other – Proposed structure shall not be located on existing drainfield. System flagged onsite. Proposed structure shall be relocated to meet septic setbacks. Proposed structure shall be flagged onsite.**

Your application will be put on hold until the selected items above have been addressed. When completed **call 893-7547 to confirm** that the items mentioned have been corrected, we will then reschedule your property for evaluation.

Sincerely,



Andrew Currin R.E.H.S  
Environmental Health Specialist  
Harnett County Department of Public Health

AC/kh  
Copy - Central Permitting