

May 8th, 2019

Cody McClam
186 Hidden Valley Dr
Holly Springs, NC 27540

RE: Existing Tank Application # BRES1904-0042

Mr. McClam,

An attempt was made to evaluate your property for the purpose of issuing an existing tank permit. The evaluation could not be completed for one or more of the following reasons.

___ 1. Uncover Outlet lid on septic tank and break seal. (\$25.00 fee incurred).

___ 2. Have system pumped out

___ 3. Replace Sanitary T

X 4. Other – Septic encroachment-proposed garage located in existing septic field. 5ft setback required away from existing septic area. Garage shall be relocated/revised for approval.

Your application will be put on hold until the selected items above have been addressed. When completed **call 893-7547 to confirm** that the items mentioned have been corrected, we will then reschedule your property for evaluation.

Sincerely,



Andrew Currin, R.E.H.S
Environmental Health Specialist
Harnett County Department of Public Health

AC/kh
Copy - Central Permitting