

CERTIFICATE OF COMPLETION / OPERATIONAL PERMIT




Name: (owner) JL Brown Bldg Inc New Installation Septic Tank
Property Location: SR# 210N Repairs Nitrification Line
Subdivision Kinnis Creek Lot # 16
TAX ID# _____ Quadrant # _____
Contractor: Larry Sharpe Registration # 29
Basement with Plumbing: Garage:
Water Supply: Well Public Community 3 Bedrooms
Distance From Well: _____ ft.

Following are the specifications for the sewage disposal system on above captioned property.

Type of system: Conventional Other _____
Size of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallons
Subsurface Drainage Field: No. of ditches 2 exact length of each ditch 150 ft. width of ditches 3 ft. depth of ditches 36 in.
French Drain: _____ Linear feet

Date: 5-23-94
Inspected by: James E. Matlock
Environmental Health Specialist

PERMIT NO. 05019



KINNIS Creek DR.

IMPROVEMENT PERMIT

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department".

Name: (owner) J. L. Brown Bldg., Inc New Installation Septic Tank

Property Location: SR# 210 N / left onto Repairs Nitrification Line

JAMES NORRIS turn N onto Kinnis Creek Dr / lot on left

Subdivision Kinnis Creek Estates Lot # 16

Tax ID# _____ Quadrant # _____

Number of Bedrooms Proposed: 3 Lot Size: _____

Basement with Plumbing: Garage:

Water Supply: Well Public Community

Distance From Well: _____ ft.

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system: Conventional Other _____

Size of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallons

Subsurface Drainage Field No. of ditches 2 exact length of each ditch 150 ft. width of ditches 3 ft. depth of ditches 36 in.

French Drain required: _____ Linear feet

This permit is subject to revocation if site plans or intended use change.

Date: 3/5/94

Signed: [Signature]

Environmental Health Specialist

VOID AFTER 5 YEARS

House may be moved to within 55'

