

OPERATIONS PERMIT

Name: (owner) Lambert Homes Inc New Installation Septic Tank
 Property Location: SR# 1443 Repairs Nitrification Line
 Subdivision South Ridge Farms Lot # 56
 TAX ID# _____ Quadrant # _____
 Contractor: Jenny Stevens Registration # _____


Basement with Plumbing: Garage:
 Water Supply: Well Public Community
 Distance From Well: 50' ft.

Following are the specifications for the sewage disposal system on above captioned property.

Type of system: Conventional Other _____
 Size of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallons
 Subsurface Drainage Field: No. of ditches 2 exact length of each ditch 150 ft. width of ditches 3 ft. depth of ditches 18-24 in.
 French Drain: - Linear feet

Date: _____
 Inspected by: James E. Moorhead
 Environmental Health Specialist

PERMIT NO. 14737



IMPROVEMENT PERMIT

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No Person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department."

Name: (owner) Lambert Homes Inc

New Installation Septic Tank

Property Location: SR# 1443

Repairs Nitrification Line

Subdivision South Ridge Farms Lot # 56

Tax ID # _____ Quadrant # _____

Number of Bedrooms Proposed: 3 Lot Size: 30p47

Basement with Plumbing: Garage:

Water Supply: Well Public Community

Distance From Well: 50' ft.

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system: Conventional Other _____

Size of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallons

Subsurface Drainage Field No. of ditches 2 exact length of each ditch 150 ft. width of ditches 3 ft. depth of ditches 18-24 in. ^{max}


French Drain Required: _____ Linear feet

Date: 5-5-98

This permit is subject to revocation if site plans or intended use change.

Signed: James C. Manhart R.S.
Environmental Health Specialist

-200



- *Maintain all setbacks!
- *NITRIFICATION LINES NO DEEPER THAN 24"!
- *Pump may be required to install system correctly because of Decks + storage AREA attached to Home!