ROBERT J. BRACKEN, P.E. 3768 CARBONTON RD. SANFORD, N.C. 27330



TELEPHONE (919) 774-6074 BJBRACKEN@WINDSTREAM.NET

	DEL BUILDERS P.O. BOX 994 SANFORD, NC 27330	PROJECT NO. 3119 INVOICE DATE Way 30, 2019
. 100 000 000 000 000		
*****************	ALL ACCOUNTS DUE IN 30 DAYS.	PLEASE DETACH AND MAIL TOP PORTION WITH YOUR REMITTANCE.
	FOOTING	INSPECTION
	hand	Pef: 317 Vick Keith Da Santor d
		AMOUNT DUE 4350°

RJB, P.E., P.A.

C-0269

ROBERT J. BRACKEN ENGINEER * SURVEYOR

3768 Carbonton Road • Sanford, North Carolina 27330 (919) 774-6074 • bjbracken@windstream.net

May 30, 2019,

Harnett County Building Inspections P.O. Box 65 Lillington, NC 27546

> REF: Footing Inspection 317 Vick Keith Rd. Sanford, NC 27332 DEL Builders, Contractor,

Dear Sir/Madam,

I made an onsite visit to the above referenced residential building site on May 28, 2019, The purpose of the visit was to follow up on the recommendations that I gave the contractor for soft soil in the footing trench. The recommendations were done and stone was placed in the under cut area and rebar was in place. I gave the contractor permission to pour the footing. The footing will support the live and dead loads per the NC State Building Code, 2018,ed.

If you have any questions please feel free to call me at 774-6074.

Sincerely,

Robert J. Bracken, PE