

# Harnett County Department of Public Health

## Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: Crystal McQuaig PROPERTY LOCATION: 35 Green Oak Trl (NC 27)  
 SUBDIVISION: Longleaf Acres LOT # 49  
 NEW  REPAIR  EXPANSION   
 Type of Structure: Existing → 4BR DWMT  
 Proposed Wastewater System Type: Conv. + 25% Red.  
 Projected Daily Flow: 480 GPD  
 Number of bedrooms: 4 Number of Occupants: 8 max  
 Basement  Yes  No  
 Pump Required:  Yes  No  May be required based on final location and elevations of facilities  
 Type of Water Supply:  Community  Public  Well Distance from well NA feet  
 Permit conditions: \_\_\_\_\_ Permit valid for:  Five years  
 No expiration

Authorized State Agent: [Signature] Date: 06/14/2019 SEE ATTACHED SITE SKETCH  
 The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

## Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: Crystal McQuaig PROPERTY LOCATION: 35 Green Oak Trl (NC 27)  
 SUBDIVISION: Longleaf Acres LOT # 49  
 Facility Type: Ext → 4BR DWMT  New  Expansion  Repair  
 Basement?  Yes  No Basement Fixtures?  Yes  No  
 Type of Wastewater System\*\* Conventional + 25% reduction (Initial) Wastewater Flow: 480 GPD  
 (See note below, if applicable   
Pump to 25% reduction (Repair)  
 Installation Requirements/Conditions  
 Septic Tank Size Ext gallons Number of trenches 2 (NEW)  
 Pump Tank Size \_\_\_\_\_ gallons Exact length of each trench 75 feet Trench Spacing: 9 Feet on Center  
 Trenches shall be installed on contour at a Maximum Trench Depth of: 12 MAX inches Soil Cover: 6 inches (IMPORT)  
 (Trench bottoms shall be level to +/-1/4" in all directions) (Maximum soil cover shall not exceed 36" above the trench bottom)  
 Pump Requirements: \_\_\_\_\_ ft. TDH vs. \_\_\_\_\_ GPM Aggregate Depth: NA inches below pipe  
NA inches above pipe  
 Conditions: GIN IMPORT COVER; CONNECT TO EXISTING AND MAKE 4-LINE EQUAL DISTRIBUTION [D.Box] NA inches total

WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA.  
 NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA.

\*\*If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.  
 Owner/Legal Representative Signature: \_\_\_\_\_ Date: \_\_\_\_\_

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH

Authorized State Agent: [Signature] Date: 06/14/2019  
ANDREW WARRIS Construction Authorization Expiration Date: 06/14/2024

HTE# BLES1905-0068


Permit # NA

# Harnett County Department of Public Health Site Sketch

ISSUED TO: Crystal McQuig PROPERTY LOCATOR: 35 Greenoak Trl (NC 27)  
SUBDIVISION: Long Leaf Acres LOT # 49

Authorized State Agent: [Signature] Date: 06/14/2019  
ANDREW CURRIN

- \* TWO (2) 75FT 25% REDUCTION NEW LINES
- \* 12IN MAX W/ IMPORT COVER
- \* ADD 6IN IMPORT COVER TO LOW SPOT ON EXISTING LINES [MIDDLE OF BACK]



\* NO EXISTING PERMIT

↳ LIKELY REPLACE D-BOX AND MAKE 4 LINES OF EQUAL DIST.

↳ CONTACT EH PRIOR TO INSTALL TO CONSULT

