

June 21st, 2019

Robert Randall Pearce
345 Dewar Street
Fuquay Varina, NC 27526

RE: Existing Tank Application # BRES1906-0001

Mr. Pearce,

An attempt was made to evaluate your property for the purpose of issuing an existing tank permit. The evaluation could not be completed for one or more of the following reasons.

___ 1. Uncover Outlet lid on septic tank and break seal. (\$25.00 fee incurred).

___ 2. Have system pumped out

___ 3. Replace Sanitary T

X 4. Other – Proposed pool encroaches on existing septic area. Proposed pool shall be 15ft from existing system. Revision required.

Your application will be put on hold until the selected items above have been addressed.

When completed **call 893-7547 to confirm** that the items mentioned have been corrected, we will then reschedule your property for evaluation.

Sincerely,



Andrew Currin, R.E.H.S
Environmental Health Specialist
Harnett County Department of Public Health

AC/kh

Copy - Central Permitting