

Harnett County Government Complex
307 W. Cornelius Harnett Boulevard
Lillington, NC 27546

ph: 910-893-7547
fax: 910-893-9371

June 28th, 2019

Veronica Torres
4917 Reconciliation Drive
Raleigh, NC 27603

Re: Status of Permit Applications– BRES1906-0032

Ms. Torres,

An attempt was made to evaluate your property for the purpose of issuing an Improvement Permit. The evaluation could not be completed for one or more of the following reasons.

- 1. Use pink flags to mark property lines and irons that are set by surveyor need to be visible. (\$25.00 Fee incurred)**
- 2. Use orange flags to mark house box.
- 3. Directions not clear to property (*\$25.00 fee incurred*)
- 4. Property needs cleared prior to permitting
- 5. Driveway not shown on site plan (Revision Required)**
- 6. Backhoe pits maybe required
- 7. Other- Setbacks shall be verified and modified based on survey irons and property lines (revision may be required).**

Your application will be put on hold until the selected items above have been addressed.

When completed **please call 910-893-7547 to confirm** that the items mentioned have been corrected, we will then reschedule your property for evaluation.

Sincerely,



Andrew Currin, R.E.H.S
Environmental Health Specialist
Harnett County Department of Public Health

AC/kh
Copy: Central Permitting