

OPERATIONS PERMIT

Name: (owner) Greg Hepp New Installation Septic Tank
 Property Location: SR# 1437 Ballard Rd Repairs Nitrification Line
 Subdivision _____ Lot # _____
 TAX ID# _____ Quadrant # _____
 Contractor: Tommy Coley Registration # _____


Basement with Plumbing: Garage:
 Water Supply: Well Public Community
 Distance From Well: 50' ft.

Following are the specifications for the sewage disposal system on above captioned property.

Type of system: Conventional Other _____
 Size of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallons
 Subsurface No. of 2 exact length 105 width of _____ depth of _____
 Drainage Field ditches 3 of each ditch 70 ft. ditches 3 ft. ditches 18 in.
 French Drain: _____ Linear feet

Date: 10-19-01
 Inspected by: James E. Marshall
 Environmental Health Specialist

PERMIT NO. 17953



01-5-1455

HARNETT COUNTY HEALTH DEPARTMENT

No 17953

IMPROVEMENT PERMIT

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No Person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department."

Name: (owner) Greg H. pp New Installation Septic Tank
Property Location: SR# 1437 Ballard Rd. Repairs Nitrification Line

Subdivision _____ Lot # _____

Tax ID # _____ Quadrant # _____

Number of Bedrooms Proposed: 3 Lot Size: 60 Ac

Basement with Plumbing: Garage:

Water Supply: Well Public Community

Distance From Well: 50 min ft.

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system: Conventional Other _____

Size of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallons

Subsurface Drainage Field No. of ditches 3 exact length of each ditch 70 ft. width of ditches 3 ft. depth of ditches 18 in. MAX

French Drain Required: _____ Linear feet

Date: 4/4/2001

This permit is subject to revocation if site plans or intended use change.

Signed: Bryan McSwain R.S.
Environmental Health Specialist

- * Maintain all setbacks
- * Run ditches on contour if possible
- * Use step downs when needed
- * Contractor to meet on-site prior to installing system

