

Harnett County Department of Public Health

Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: John and Amanda Stanley PROPERTY LOCATION: 1060 Womack Rd, Broadway
 NEW REPAIR EXPANSION SUBDIVISION _____ LOT # _____
 Type of Structure: Manufactured DW 58' x 30.4' Site Improvements required prior to Construction Authorization Issuance: _____
 Proposed Wastewater System Type: 25% Reduction _____
 Projected Daily Flow: 360 GPD _____
 Number of bedrooms: 3 Number of Occupants: 6 max _____
 Basement Yes No _____
 Pump Required: Yes No May be required based on final location and elevations of facilities _____
 Type of Water Supply: Community Public Well Distance from well 50+ feet Permit valid for: Five years
 Permit conditions: _____ No expiration

Authorized State Agent: [Signature] Date: 8/9/14 SEE ATTACHED SITE SKETCH
 The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: John and Amanda Stanley PROPERTY LOCATION: 1060 Womack Rd, Broadway
58' x 30.4' SUBDIVISION _____ LOT # _____
 Facility Type: Manufactured DW New Expansion Repair
 Basement? Yes No Basement Fixtures? Yes No
 Type of Wastewater System** 25% Reduction (Initial) Wastewater Flow: 360 GPD
 (See note below, if applicable Pump to LDP (Repair)
Installation Requirements/Conditions
 Septic Tank Size 1000 gallons Number of trenches 4
 Pump Tank Size _____ gallons Exact length of each trench 75 feet
 Trenches shall be installed on contour at a Trench Spacing: 9 Feet on Center
 Maximum Trench Depth of: 18 inches Soil Cover: 6 inches
 (Trench bottoms shall be level to +/- 1/4" (Maximum soil cover shall not exceed
 in all directions) 36" above the trench bottom)
 Pump Requirements: _____ ft. TDH vs. _____ GPM Aggregate Depth: _____ inches below pipe
 _____ inches above pipe
 _____ inches total

**WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA.
 NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA.**

**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.
 Owner/Legal Representative Signature: _____ Date: _____

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH

Authorized State Agent: [Signature] Date: 8/9/14
[Signature] Construction Authorization Expiration Date: 8/9/24

HTE# BRES1907-0024

Permit # _____

Harnett County Department of Public Health Site Sketch

ISSUED TO: John and Amanda Stanley PROPERTY LOCATOR: 1060 Wornack Rd, Broadway
SUBDIVISION _____ LOT # _____

Authorized State Agent: Bobby Ach ~~REHS~~ REHS-I Date: 8/7/19

This drawing is for illustrative purposes only.
System installation must meet all
Pertinent laws, rules, and
regulations.

