



Matt Brueshaber, PE  
Stonewall Structural Engineering, PLLC  
4800 Falls of Neuse Rd. #120  
Raleigh, NC 27609  
(919)407-8663

Randy Miller  
171 Clearview Ct.  
Sanford, NC 27332

Re: Structural Observation—171 Clearview Court, Sanford, NC 27332

Mr. Miller,

At your request, on August 14<sup>th</sup>, 2019 we performed a visual structural observation of newly-poured concrete slabs for garage and screen porch additions at the Sanford residence noted above (see pictures 1-4 for examples).

After reviewing photo documentation provided by the client of the footings prior to filling with concrete, and performing on-site probing and measurements, we have determined that the subject slabs and footings were constructed in accordance with the intent of the 2018 NC Residential Building Code, and are adequate to be built upon.


The above-listed determinations were made in accordance with common engineering principles and the intent of the 2018 edition of the North Carolina Residential Building Code. Sequencing, and means and methods of construction are considered to be beyond the scope of this report. Contractor is to provide adequate temporary shoring prior to cutting or removing any structural load-bearing elements. All work is to conform to applicable provisions of current building standards. Please feel free to contact us, should you have any questions or concerns regarding this matter.

Sincerely,


Matt Brueshaber, PE

Stonewall Structural Engineering, PLLC

Lic. #P-0951



PICTURE ADDENDUM



Picture 1 – 171 Clearview Court,  
Sanford, NC



Picture 2 – Example of new garage slab



Picture 3 – Example of new porch slab



Picture 4 – Example of new footing along back  
perimeter of proposed screened porch addition