

HTE #: BRES1907-0049

HARNETT COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH
307 CORNELIUS HARNETT BOULEVARD
LILLINGTON, NC 27546

EXISTING SEPTIC SYSTEM INSPECTION

Name: Carolina Custom Builders Phone #: 919-790-1234

Address: 4905 Departure Dr., Raleigh

Name of Mobile Home Park or S/D: Eastmill

Name of Owner (if different): Joeph and Marilyn Jamal

Address of Owner (if different): 8253 NC 42 Hwy 42, Hollysprings

Property Location (State Road name and #): NC 42

Purpose of Inspection: Garage Addition


The aforementioned site has been evaluated by the Harnett County Health Department Environmental Health Section. At the time of inspection, there appeared to be a septic system serving this site. If the system should malfunction, the owner is responsible for any necessary repairs.

THIS INSPECTION IS VOID IF:

1. the intended use of the septic system should change, and/or
2. the system should fail or malfunction, and/or
3. the owner or tenant of the property change, and/or
4. after six months

**BUILDING MUST BE 5' FROM ANY PART OF SEPTIC SYSTEM
DO NOT DRIVE OR PARK ON SEPTIC SYSTEM**

AUTHORIZATION OF EXISTING SYSTEM

 REHS-I

Signature of Environmental Health Specialist

8/5/19

Date