

Permit Inspections Harnett County

Permit Number: BRES1908-0045

Description: 6x30 deck replacement like for like

Applied: 8/22/2019	Approved: 8/22/2019	Site Address: 968 AZALEA DR
Issued: 8/22/2019	Finaled:	City, State Zip Code: SPRING LAKE, NC 28390
Status: ISSUED		Applicant: NORTHPOINT LAKE CHARLES LLC
Parent Permit:		Owner: NORTHPOINT LAKE CHARLES LLC
Parent Project:		Contractor: NORTHPOINT LAKE CHARLES LLC

Details:

LIST OF INSPECTIONS								
SEQ ID	SCHEDULED DATE	COMPLETED DATE	ТҮРЕ	INSPECTOR	RESULT	REMARKS		
			FINAL**	Ray Holder				
Notes:								
			TAX INSPECTION	Tax Inspection				
Notes:								
			FOOTING	Slade Burton Lawson III				
Notes:								
	11/15/2019	11/15/2019	FOOTING	Slade Burton Lawson III	DISAPPROVED			
Notes:								
Inspector RLH changed the inspection assignment from RLH to SBL								
Unable to verify depth of footing. Need engineer letter stating footings were placed per code								

