

# WENK ENGINEERING

30 January 2020

Four Oaks Residential, LLC  
Attn: Mr. Christopher Santoro  
5127 US Hwy 301 S  
Four oaks, NC 27542-1178

Re: 1364 Rosser Pittman Rd.  
Broadway, NC

Mr. Santoro,

I made a site visit to the above property on 30 January 2020. The purpose of my visit was to make a visual evaluation of the foundation for the garage. The excavation had water in several places and the soil is clay which will hold the water until drained or pumped. Probing the bottom of the trench the soil was hard. I suggested to those on site to dewater with the pump on site, place the 57 stone on site into the trench to the proper level and hand compact until the stone was firm in place then place the footer.

Sincerely,



C. M. Wenk, P.E.

