

Harnett County Government Complex
307 W. Cornelius Harnett Boulevard
Lillington, NC 27546

ph: 910-893-7547

fax: 910-893-9371

October 4, 2019

Kenneth Brown
PO Box 501
Fuquay Varina, NC 27526

RE: Existing Tank Application # BRES1909-0040

Mr. Brown,

An attempt was made to evaluate your property for the purpose of issuing an existing tank permit. The evaluation could not be completed for one or more of the following reasons.

1. **Uncover Outlet lid on septic tank and break seal. (\$25.00 fee incurred).**

2. Have system pumped out

3. Replace Sanitary T

4. **Other – Septic system sized for two 2-bedroom SWMH (4-bedroom Max). SWMH shall be placed exactly where old was. The septic tank was not uncovered for inspection. Property irons and lines shall be marked by surveyor and setbacks maintained. DWMH moved onto the lot without approval. The DWMH placed across property lines.**

Your application will be put on hold until the selected items above have been addressed. When completed **call 893-7547 to confirm** that the items mentioned have been corrected, we will then reschedule your property for evaluation.

Sincerely,



Andrew Currin, R.E.H.S
Environmental Health Program Specialist
Harnett County Department of Public Health

AC/slc
Copy - Central Permitting