

HTE #: BRES1909-0040

HARNETT COUNTY HEALTH DEPARTMENT  
ENVIRONMENTAL HEALTH  
307 CORNELIUS HARNETT BOULEVARD  
LILLINGTON, NC 27546

**EXISTING SEPTIC SYSTEM INSPECTION**

Name: Kenneth Brown

Phone #: 919.337.8460

Address: PO Box 501 Fuquay-Varina, NC 27526

Name of Mobile Home Park or S/D: Olena Davis Lot 4

Name of Owner (if different): Same

Address of Owner (if different): Same

Property Location (State Road name and #): 41 Olena Drive (Ballard Rd. - SR 1437)

Purpose of Inspection: 3-bedroom 24'x60' Manufactured Home

**The aforementioned site has been evaluated by the Harnett County Health Department Environmental Health Section. At the time of inspection, there appeared to be a septic system serving this site. If the system should malfunction, the owner is responsible for any necessary repairs.**

**THIS INSPECTION IS VOID IF:**

1. the intended use of the septic system should change, and/or
2. the system should fail or malfunction, and/or
3. the owner or tenant of the property change, and/or
4. after six months

**BUILDING MUST BE 5' FROM ANY PART OF SEPTIC SYSTEM  
DO NOT DRIVE OR PARK ON SEPTIC SYSTEM**

AUTHORIZATION OF EXISTING SYSTEM

  
Signature of Environmental Health Specialist

02/18/2020

Date