

01-5-2273

**WARNETT COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH SECTION**

No 13668

OPERATIONS PERMIT

Name: (owner) A.L. Champion

New Installation

Septic Tank

Property Location: SR# 1443 Lafayette Rd

Repairs

Nitrification Line

Subdivision Victoria Hills II

Lot # 052

TAX ID# _____

Quadrant # _____

Contractor: Ray Moore

Registration # _____

Basement with Plumbing:

Garage:

Water Supply: Well

Public

Community

Distance From Well: 50' ft.

Following are the specifications for the sewage disposal system on above captioned property.

Type of system: Conventional

Other _____

Size of tank: Septic Tank: 1000 gallons

Pump Tank: _____ gallons

Subsurface Drainage Field: No. of ditches 1, exact length of each ditch 30 ft., width of ditches 3 ft., depth of ditches 18-20 in.


French Drain: — Linear feet

01-5-2273

Date: 4-23-02

PERMIT NO. 18456

Inspected by: James E. Mark
Environmental Health Specialist



IMPROVEMENT PERMIT

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No Person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department."

Name: (owner) A L Champion

New Installation Septic Tank

Property Location: SR# 1443 Lafayette School

Repairs Nitrification Line

Subdivision Victoria Hills II Lot # 232

Tax ID # _____ Quadrant # _____

Number of Bedrooms Proposed: 3 Lot Size: 30,918 sq ft

Basement with Plumbing: Garage:

Water Supply: Well Public Community

Distance From Well: 50' ft.

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system: Conventional Other _____

Size of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallons

Subsurface Drainage Field No. of ditches 1 exact length of each ditch 300 ft. width of ditches 3 ft. depth of ditches 18-20 in.

French Drain Required: — Linear feet

Date: 7-5-01

This permit is subject to revocation if site plans or intended use change.

Signed: James E. Mantel, M.S.
Environmental Health Specialist

* Maintain all setbacks

