

HTE #: BRES1910-0034

HARNETT COUNTY HEALTH DEPARTMENT  
ENVIRONMENTAL HEALTH  
307 CORNELIUS HARNETT BOULEVARD  
LILLINGTON, NC 27546

**EXISTING SEPTIC SYSTEM INSPECTION**

Name: Mark Duntz Phone #: 910-309-3001

Address: 316 Royal Pines Ln, Lillington

Name of Mobile Home Park or S/D: \_\_\_\_\_

Name of Owner (if different): \_\_\_\_\_

Address of Owner (if different): \_\_\_\_\_

Property Location (State Road name and #): SR Old US 421

Purpose of Inspection: 35'x100' Storage Building


**The aforementioned site has been evaluated by the Harnett County Health Department Environmental Health Section. At the time of inspection, there appeared to be a septic system serving this site. If the system should malfunction, the owner is responsible for any necessary repairs.**

**THIS INSPECTION IS VOID IF:**

1. the intended use of the septic system should change, and/or
2. the system should fail or malfunction, and/or
3. the owner or tenant of the property change, and/or
4. after six months

**BUILDING MUST BE 5' FROM ANY PART OF SEPTIC SYSTEM  
DO NOT DRIVE OR PARK ON SEPTIC SYSTEM**

AUTHORIZATION OF EXISTING SYSTEM

 REHS-I 11/1/19  
Signature of Environmental Health Specialist Date