



Harnett County
108 EAST FRONT STREET
LILLINGTON, NC 27546
Phone:
Fax:

12/19/2019

SUBJECT: BRES1910-0047
BUILDING RESIDENTIAL

To: Joshua McLamb

Here are the results of all Inspections located at **147 E MAIN ST:**

Inspection Type: FOOTING
Scheduled Date/Time: 10/29/2019
Completed Date/Time: 10/29/2019
Inspector: Deen Taylor
Result: APPROVED
Remarks:
Notes:

Inspection Type: FINAL**
Scheduled Date/Time: 11/19/2019
Completed Date/Time: 11/19/2019
Inspector: Steven Gazlay
Result: DISAPPROVED
Remarks:
Notes: Inspector RLH changed the inspection assignment from RLH to SPG
Handrails must be between 34" and 38" to top of handrail. Must use 2x4 for hand grip portion.

Inspection Type: TAX INSPECTION
Scheduled Date/Time: 11/19/2019
Completed Date/Time: 11/22/2019 PM
Inspector: Terry Wade
Result: APPROVED
Remarks:
Notes: 11/22/19;Remodeling/addition(WDD)for 2020.tw

Inspection Type: FINAL**
Scheduled Date/Time: 11/26/2019
Completed Date/Time: 11/26/2019
Inspector: Steven Gazlay
Result: APPROVED
Remarks:
Notes: