

HTE# BZES 1911-0020

HARNETT COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH
307 CORNELIUS HARNETT BOULEVARD
LILLINGTON, NC 27546

EXISTING SEPTIC SYSTEM INSPECTION

NAME: Kevin Chlopek PHONE # 919-279-7199

ADDRESS 451 OWENS RD Angier N.C. 27526

NAME OF MOBILE HOME PARK OR S/D _____

NAME OF OWNER (IF DIFFERENT) _____

ADDRESS OF OWNER (IF DIFFERENT) _____

PROPERTY LOCATION: STATE ROAD NAME AND # SR 1539 OWENS RD

PURPOSE OF INSPECTION: Storage Personal 30x51

The aforementioned site has been evaluated by the Harnett County Health Department Environmental Health Section. At the time of inspection, there appeared to be a septic system serving this site. If this system should malfunction, the owner is responsible for any necessary repairs.

- THIS INSPECTION IS VOID IF:
- (1) the intended use of the septic system should change, and/or
 - (2) the system should fail or malfunction, and/or
 - (3) the owner or tenant of the property changes, and/or
 - (4) after six months

**BUILDING MUST BE 5' FROM ANY PART OF SEPTIC SYSTEM
DO NOT DRIVE OR PARK ON SEPTIC SYSTEM**

AUTHORIZATION OF EXISTING SYSTEM

James E. Montanaro 12/2/19
Signature of Environmental Health Specialist

12-2-19
Date