

December 19, 2019

Peter Specht
88 Woodland Ridge Drive
Fuquay Varina, NC 27526

RE: Existing Tank Application # BRES1912-0007

Mr. Specht,

An attempt was made to evaluate your property for the purpose of issuing an existing tank permit. The evaluation could not be completed for one or more of the following reasons.

___ 1. Uncover Outlet lid on septic tank and break seal. (\$25.00 fee incurred).

___ 2. Have system pumped out

___ 3. Replace Sanitary T

4. Other – Proposed deck encroaches upon existing septic. There is a 5ft septic setback required off any deck footing.

Your application will be put on hold until the selected items above have been addressed. When completed **call 893-7547 to confirm** that the items mentioned have been corrected, we will then reschedule your property for evaluation.

Sincerely,



Andrew Currin, R. E. H. S.
Environmental Health Program Specialist
Harnett County Department of Public Health

AC/slc
Copy - Central Permitting