

CERTIFICATE OF COMPLETION / OPERATIONAL PERMIT

Name: (owner) Leon Anderson Const New Installation Septic Tank
 Property Location: SR# 1415 Repairs Nitrification Line
 Subdivision Woodland Ridge Lot # 21
 Contractor: Odell Johnson Registration # 78

Basement with Plumbing: Garage:
 Water Supply: Well Public Community
 Distance From Well: 50' ft. all others


Following are the specifications for the sewage disposal system on above captioned property.

Type of system: Conventional Other _____
 Size of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallons
 Subsurface Drainage Field: No. of ditches 4 exact length of each ditch 90 ft. width of ditches 3 ft. depth of ditches 18-28 in.
 French Drain: _____ Linear feet

PERMIT NO. 5840

Date: 05/15/92
 Inspected by: Jul H. Byrd, S
 Environmental Health Specialist

OK checked soil.



HARNETT COUNTY HEALTH DEPARTMENT

IMPROVEMENT PERMIT

5840

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department".

Name: (owner) Leon Anderson, Const. New Installation Septic Tank
Property Location: SR 1415 Repairs Nitrification Line
Lot # 21 Woodland Ridge

Number of Bedrooms Proposed: 3 Lot Size: 1.409 acre

Basement with Plumbing: Garage:
Water Supply: Well Public Community
Distance From Well: _____ ft.

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system: Conventional Other _____
Size of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallons
Subsurface Drainage Field No. of ditches 4 exact length of each ditch 90 ft. width of ditches 3 ft. depth of ditches 18 in.
French Drain required: _____ Linear feet

This permit is subject to revocation if site plans or intended use change.

Date: 11/08/91
Signed: Charles H. Wood
Environmental Health Specialist

VOID AFTER 5 YEARS



→ Woodland Dr. to SR 1415 →